



DEPARTAMENTOS
Y LOCALES

GARI DANIEL
TINAJERO
ALTUZAR
VICTOR
MANUEL
SANTIAGO
GUILLEN

UDS
METROS
ESC: 1200

ELECTRICO
10/04/24
PLANO 1

CUADRO DE CARGAS

Cto.									Watts	Ampers	Protección Termomagnética
D1	8	1							1789	14.08	15
C2	9	1							2143	16.87	20
C3	9	1							2016	15.87	20
L1	5	4							1508	11.87	15
L2	6	3							1408	11.08	15
L3	6	3							1408	11.08	15
RG	4	12							2235	17.59	20
BG	6								1108	8.72	15
PSV		12							1581	12.44	15
Total	53	37							15471	121.81	150

TABLERO DTO. 1